



## HSF04 - Fire Safety Risk Assessment

<b>Location: Rochdale RRUFC</b>				<b>FRA No: 03</b>
<b>Persons at Risk: Staff, General Public, Members and Volunteers</b>				
<b>Sources of Ignition:</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>	<b>Other Information</b>
Are flammable substances and combustibles stored safely?	X			Flammable gas cylinders have been removed to outside container.  All passages are clear  All portable equipment PAT tested in August 2017 and annual checks made on electrical equipment
Are ignition sources adequately controlled?	X			
Are means of escape free from combustible materials?	X			
Are equipment and work processes managed appropriately?	X			
<b>Building Layout / Construction:</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>	<b>Other Information</b>
Are the means of escape provided sufficient?	X			Building now 10 years old and built to building regs no structural alterations since that date  All fire doors fitted with intumescent strips and half hour rated
Is the fire separation of compartments adequate?	X			
Are doors, where necessary, to the required standard of fire resistance?	X			
Are the travel distances to a place of safety within acceptable standards?	X			
Is door furniture on escape routes to an acceptable standard?	X			
Are exit widths and direction of door opening acceptable?	X			
<b>Means of Detection:</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>	<b>Other Information</b>
Is a suitable fire alarm fitted in this area in relation to the risks?	X			Fire detectors and alarms fitted throughout the building. Weekly checks carried out
<b>Emergency Lighting:</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>	<b>Other Information</b>
Is the emergency lighting fitted to a satisfactory level?	X			Checked annually by ADT under contract
<b>Fire Fighting Equipment:</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>	<b>Other Information</b>
Is fire-fighting equipment provided in this area?	X			All extinguishers were checked in July 2017
Is the fire-fighting equipment suitably sited?	X			
Do extinguishers have the correct signage fitted?	X			
<b>Fire Signage / Notices:</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>	<b>Other Information</b>
Is the safety signage provided to the required standard?	X			All fire points have correct signage New exit signs displayed Meeting point between first XV pitch and B team pitch
Does fire signage conform to the signs and signals regulations 1996?	X			
<b>Date of Assessment: 24.11.2017</b>		<b>Assessor: R G Fitton</b>		